

## EPA Discharge & Monitoring Point 19

### Southern Module Yard Blowout Point (Southern Wall of Levee)

2020-2021 Annual Return	Pollutant	Unit	Sample Date 11/03/2021	Lowest Sample	Highest Sample	Mean of Sample
	pH Value	ph Unit	7.28	7.28	7.28	7.28
	Electrical Conductivity	uS/cm	59	59	59	59
	Total Dissolved Solids	mg/L	38	38	38	38
	Suspended Solids	mg/L	986	986	986	986
	Nitrate + Nitrate as N	mg/L	0.26	0.26	0.26	0.26
	Total Kjeldahl Nitrogen as N	mg/L	<0.5	<0.5	<0.5	<0.5
	Total Nitrogen as N	mg/L	<0.5	<0.5	<0.5	<0.5
	Total Phosphorus as P	mg/L	0.81	0.81	0.81	0.81
	Oil & Grease	mg/L	7	7	7	7



### EPA Discharge & Monitoring Point 21

#### Discharge from Water Storage Dam (Northwestern Corner of Levee)

2020-2021 Annual Return	Pollutant	Unit	Sample Date					Lowest Sample	Highest Sample	Mean of Sample
			5/01/2021	25/02/2021	1/03/2021	9/03/2021	11/03/2021			
	pH Value	ph Unit	N/A	7.64	7.46	8.06	7.72	7.46	8.06	7.72
	Electrical Conductivity	uS/cm	N/A	154	126	238	116	116	238	159
	Total Dissolved Solids	mg/L	N/A	100	82	155	75	75	155	103
	Suspended Solids	mg/L	1450	418	686	575	611	418	1450	748
	Nitrate + Nitrate as N	mg/L	0.49	0.36	0.65	0.06	0.61	0.06	0.65	2.17
	Total Kjeldahl Nitrogen as N	mg/L	1.20	1.60	1.40	1.20	<0.50	<0.50	1.6	1.35
	Total Nitrogen as N	mg/L	1.70	2.00	2.00	1.30	0.60	0.6	2	1.52
	Total Phosphorus as P	mg/L	1.03	0.72	0.79	0.46	0.72	0.46	1.03	0.74
Oil & Grease	mg/L	N/A	<5	<5	<5	5	<5	5	1	