

LABORATORY ANALYSIS REPORT
Water Analysis Results

Report No: WQR28363-R02

Report Date: 05/11/2024

Client: Australian Food and Fibre

Sampled From: Warren Gin

Client Address: 74 Herber Street
Moree
NSW 2400

Sampled By: Client

Sampling Date: 16/10/2024

Attention: Craig Gaston

Test Method: In accordance with the Australia and New Zealand Guidelines for Fresh and Marine Water Quality, Volume 1, The Guidelines (2000), Australian and New Zealand Environment and Conversation Council & Agriculture and Resource Management Council of Australia and New Zealand

Sample Number	Sample Location	pH (pH Units)	Total Suspended Solids (TSS) (mg/L)	Oil & Grease (mg/L)	Comments
W28363-S1	Distribution Point 4	6.47	357	<5	

*EPA Protection Licence Section 55 Protection of the Environment Operations Act 1997	
pH	6.5-8.5
TSS	50 mg/L
Oil & Grease	10 mg/L



Laboratory Scientist

Sample Analysed as Received by Ken Archer on 30th October 2024
Senior Laboratory Scientist, BSC, APP Sc, AACB, MASM

Oil and Grease in Water [AN185] Tested: 28/10/2024

			S01 - Warren Gin
			WATER
			-
			16/10/2024
PARAMETER	UOM	LOR	SE273118.001
Oil and Grease	mg/L	5	<5